

Certificate of Compliance

Certificate Number:

EX15824

Report Reference:

EX15824-20210724

Issue Date:

2024-JUNE-12

Issued to:

SAFEX FIRE SERVICES LTD

202 'A' DHANRAJ IND ESTATE SUNMILL RD X
LOWER PAREL (W) MUMBAI MH 400013 IN

This certificate confirms that representative samples of:
SPRINKLERS, AUTOMATIC AND OPEN

See addendum page for models

Has been evaluated by UL LLC in accordance with Standard(s) for
Safety:

[UL 199, Automatic Sprinklers Fire Protection Service
ULC C199, ULC Other Recognized Document for Automatic Sprinklers
Fire Protection Service]

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional
information.

This Certificate of Compliance indicates that representative samples of
the product described in the certification report have met the
requirements for UL certification. It does not provide authorization to
apply the UL Mark. Only the Authorization Page that references the
Follow-Up Services Procedure for ongoing surveillance provides
authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as
being UL Certified and covered under UL's Follow-Up Services.



David Piecuch
UL Mark Certification Program Owner



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

Certificate of Compliance

Certificate Number: EX15824
Report Reference: EX15824-20210724
Issue Date: 2024-JUNE-12

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

PENDENT AND UPRIGHT STANDARD-SPRAY SPRINKLERS
NOMINAL 5.6 K-FACTOR
SF801
SF802
SF803
SF804

STANDARD SIDEWALL-SPRAY SPRINKLERS
SF805
SF806